



**South Orange County Community College District**

**RFQ&P No. 4763-2022:  
Architectural Services  
B200 Prep Room B225 Modernization at Irvine Valley College**

**Addendum No. Two (2)**

**March 14, 2022**

**Nick Newkirk , Purchasing and Contracts Manager**

**Note:**

**All documents remain unchanged except section or parts added to, revised, deleted and/or clarified by this Addendum.**

1. The responses to the final RFIs submitted via email on Friday, March 11, 2022 are shown below:

Q1: Does the new hood require a new exhaust fan or would it be using an existing exhaust fan?

A1: Clarification: There are 2-existing Fume Hoods in our subject Prep Room B225. Both Fume Hoods are required to be replaced with new. The assumption for this project will be to replace the existing Exhaust Fan that will serve the 2-new Fume Hoods.

Q2: What is the extent of existing utilities/ductwork that will require rework for this project?

A2: The assumption will be that all associated ductwork be reworked & replaced.